




1



2



3



4



5



6

CONTRACTOR?  
 HOMEOWNER?  
 HYDRAULICALLY  
 SOUND?  
 CODE COMPLIANT?



7

TESTING  
 VS  
 MAINTENANCE

- WHY DO TESTER'S PASS AN ASSEMBLY?
  - DID IT ACTUALLY MEET TEST STANDARDS?
  - CAN THE TESTER REPAIR IF NEEDED?
  - WHAT IS THE COMPANY'S CULTURE?
- WHY DO TESTER'S FAIL AN ASSEMBLY?
  - DID THE ASSEMBLY NOT MEET THE STANDARDS?
  - PERFORMANCE STANDARDS?
  - INSTALLATION GUIDELINES?
  - TEST REPORT REQUIREMENTS?



8

INSTALLATION

- DOES YOUR WATER AUTHORITY HAVING JURISDICTION DICTATE INSTALLATION REQUIREMENTS?
- OSY VS NRS VALVES? - 2" OR SMALLER?
- SHARKBITE FITTINGS OR SWEATED SOLDER FITTINGS?
- HEIGHT AND DISTANCE FROM OBSTRUCTIONS OR ELECTRICAL OR OTHER DANGEROUS OBJECTS.
- OTHER REQUIREMENTS



9

\$13,000.00 USD

- 8" DOUBLE CHECK
- VAULT INSTALLATION
- FIRE SUPPRESSION
- FIRE SERVICE COMPANY HIRED SUB CONTRACTOR (PLUMBER) TO TEST
- COULD NOT TEST DUE TO VALVES NOT CLOSING
- RECOMMEND REPLACEMENT
- ASSEMBLY LESS THAN 4 YEARS OLD

10

EDUCATION OR INTEGRITY?

"IS THIS THE QUESTION WE SHOULD BE ASKING?"

11