


1



2



3



4




5




6

## What's New at the USC Foundation?




7

## What's New?





- Paul H. Schwartz –
- Retired
- Grandpa of three



8

## What's New?

- USC FCCCHR Anniversary
- Established on September 14, 1944
- (September 14, 2024)


9



10

## New Approvals

- New Assemblies
- Modifications, Re-design & upgrades
- Removals
- Latest List – January 1, 2025

Foundation for Cross-Connection Control and Hydraulic Research

List of Approved Backflow Prevention Assemblies

USC University of Southern California

Foundation for Cross-Connection Control and Hydraulic Research



11

## USC List of Approved Assemblies USC List – Suspension


- Assembly Under Suspension

ASSEMBLIES UNDER SUSPENSION

AS OF SEPTEMBER 14, 2024

USC University of Southern California

Foundation for Cross-Connection Control and Hydraulic Research



- AS PART OF AN ASSEMBLY'S ONGOING APPROVAL PROCESS, MANUFACTURERS ARE REQUIRED TO SUBMIT SELECTED ASSEMBLIES FOR REVIEW AND RE-EVALUATION.
- WHEN A MANUFACTURER FAILS TO PROVIDE A REQUIRED ASSEMBLY, THE ASSEMBLY'S APPROVAL IS SUSPENDED. ONCE THE ASSEMBLY SATISFACTORILY COMPLETES THE RENEWAL REVIEW AND RE-EVALUATION, THE SUSPENSION WILL BE REMOVED.

12



13




14




15



16




17



18

Evolution of the Backflow Prevention Assembly  
Field Testing Procedures



19

Abstract

Review how the field testing procedures for the backflow prevention assemblies developed and evolved throughout the years and the reasons why they changed for the better.


20

Discussion

How long have we had Backflow Preventers?


21

1903




22

July 6, 1909




23


May 22, 1934



24



25



26

June 30, 1930 - 50<sup>th</sup> AWWA Conference in St Louis, MO

- Committee #8 Formed on Cross-Connection Control
  - No cross connections should be permitted, and existing CC should be eliminated in shortest practical time
  - If elimination is impractical, water shall be connected thru a lab tested Check Valve properly installed, regularly tested and periodically cleaned & repaired.

27

Swing Check Valve

Closed      Opened

28

Closed ?

29

One is adequate, Two is good, Three is better, etc.


30

Problems with Multiple Check Valves

- Long End to End Dimension
- Excessive pressure loss


31

Two Check Valves  
Reasonable/Practical Solution



Primary Secondary


32



Both Checks are holding tight, I think?


33

Test Effectiveness of Check Valves ?




34

Single Hose - Full Backpressure




35

Full Backpressure - How Much?




20 PSI?  
150 PSI?


36




37




38




39



40




41



42

Field Test



Record backpressure when check valve “shuts in”

43

“FIELD” Test Goals

- Insitu (in-place or original position)
- Static (non-flowing)
- Operation of Components
- “Field” vs “Laboratory” Tests


44

Goal - Insitu

- Field Test Without Having to Remove From Pipeline
- Early check arrangements had to be removed from line for inspection or testing

45

Testcocks




46

Goal - Static

- No Flow Through the backflow preventer Under Test


47

Shutoff Valves




48







49




50




51




52



53




54



55


*Manual of Cross-Connection Control, 4th Edition-1969*

- Requirement for inline repairability



56

### In-Line Repairable



57

Goal - Operation of Components

- PREVENT BACKFLOW

58

### Where Do the Different Field Test Procedures Come From?

- Recommended Practices
- State/Regional Requirements
- Local Requirements
- Manufacturers

59

### Some of the Field Test Procedures

- Double Check Valve
- Reduced Pressure Principle Assembly
- Pressure Vacuum Breaker
- Spill Resistant Pressure Vacuum Breaker

60


Double Check Valve Field Test Procedures

- Duplex Gage
- Sight Tube
- Differential Gage

61

*Manual of Cross-Connection Control, 1st Edition-1960*

- Field test procedures for DC (w/duplex gage)




62




63



64



65



66

*Manual of Cross-Connection Control, 9th Edition-1993*


- Field test procedure for DC changed from backpressure test to direction of flow test.

67


DC - Sight Tube Methods

- Hold 1 PSI
- Closing / opening Point

68



69




70

DC - Differential Gage

- Two hose method
  - High and Low side hoses
- One hose method
  - High side hose only

71




72

### Two Hose Method

- Can Not Perform Test Accurately if:
  - No. 2 Shutoff valve leaks
  - No. 2 Check Valve leaks
  - No. 1 Check Valve leaks
- Can Perform Test Accurately only if:
  - No. 2 Shutoff Valve is drip tight, and
  - Both Check Valves Hold Tight

73

### One Hose Method



74

### One Hose Method

- Can Test with Shutoff Valves Leak
- Determines Closing Point of Each Check Valve


75

### RP Field Test Procedures

- Visual Indication Test Procedures
- Order of Tests
- Second Check Differential

76

### RP Test Procedures using a single hose



**HERSEY-SPARLING METER COMPANY**  
1000 W. 10th Street, Des Moines, IA 50319

**VISUAL INDICATION TEST METHOD**  
**BEECO REDUCED PRESSURE BACKFLOW PREVENTERS**

**GENERAL COMMENTS**  
 This "visual indication" test method is designed to provide a simple and inexpensive procedure for testing the proper operation of reduced pressure backflow preventers. Because no instruments are used to measure pressure differentials, Test No. 3 of the following procedure will not indicate the actual differential between supply pressure and zone pressure at which the relief valve opens. Specifications usually require this differential to be no less than 2 psi, and for this reason it is strongly recommended that a test incorporating the use of a gauge or manometer be performed on the backflow preventer at yearly intervals.

**FIELD TEST EQUIPMENT REQUIRED**

QUANTITY	DESCRIPTION
1	6' length of hose with female hose connectors at each end.
3	Hose to pipe adapters to accommodate hose to test cocks on device to be tested.

**NOTE:** Field test equipment may be ordered from HERSEY-SPARLING Meter Company.

77

### VISUAL INDICATION TEST METHOD

#### BEECO REDUCED PRESSURE BACKFLOW PREVENTERS

**GENERAL COMMENTS**

This "visual indication" test method is designed to provide a simple and inexpensive procedure for testing the proper operation of reduced pressure backflow preventers. Because no instruments are used to measure pressure differentials, Test No. 3 of the following procedure will not indicate the actual differential between supply pressure and zone pressure at which the relief valve opens. Specifications usually require this differential to be no less than 2 psi, and for this reason it is strongly recommended that a test incorporating the use of a gauge or manometer be performed on the backflow preventer at yearly intervals.

**FIELD TEST EQUIPMENT REQUIRED**


QUANTITY	DESCRIPTION
1	6' length of hose with female hose connectors at each end.
3	Hose to pipe adapters to accommodate hose to test cocks on device to be tested.

**NOTE:** Field test equipment may be ordered from HERSEY-SPARLING Meter Company.

78

*Manual of Cross-Connection Control, 1st Edition-1960*

- Field test procedures for RP (w/mercury manometer)




79




80

*Manual of Cross-Connection Control, 5th Edition-1974*

- Field test procedures for RP used differential pressure gage



81



82

**RP – Field Test Procedure**

- Relief Valve Opening Point Test
- It is one of the objectives of the field test procedure to determine the opening point value of the relief valve; the first time it opens under normal field operation.

83

**RP – Field Test Procedure**

- Relief Valve Opening Point Test
- In normal field operation, the corresponding field test should evaluate the assembly under the same conditions.

84

**RP – Field Test Procedure  
one-hose method**

- Test for Tightness of No. 1 Check Valve
- Test for Tightness of No. 2 Check Valve
- Tested Similar to a DC Test

85


**RP – Field Test Procedure  
one-hose method**

- Test No. 3 – Relief Valve Opening Point Test
- Tested at low pressure not the supply working pressure of the system or normal field operation

86

**Reduced Pressure Principle Assembly (RP)**


- Pressure Zones



87

**Reduced Pressure Principle Assembly (RP)**

- Relief Valve Pressure Zone



88


**Reduced Pressure Principle Assembly (RP)**

- Relief Valve Pressure Zone




89

**Reduced Pressure Principle Assembly (RP)**



90



91

**USC FCCCHR**  
10<sup>th</sup> Edition Manual of Cross-Connection Control

**Chapter 10 - Design, Operational and Evaluation Standard for Reduced Pressure Principle Backflow Prevention Assemblies (RP)**

**Section 10.1.2.3.1**

**Purpose:** To test the operation of the differential pressure relief valve.

**Requirement:** The differential pressure relief valve shall operate to maintain the zone between the two check valves at least 2 and 15.75 kPa less than the supply pressure but at the pressures from 20 psi (137.8 kPa) up to the maximum working water pressure, but not less than 100 psi (689.4 kPa) line pressure.

**Steps:**

1. Connect the high side hose of the differential pressure gage (or manometer) to test cock No. 2.
2. Connect the low side hose of the differential pressure gage (or manometer) to test cock No. 3.
3. Close test cocks No. 2 and No. 3 and bleed air from the gage (or manometer).
4. Close the No. 2 shutoff valve.
5. Slowly (maximum rate of 0.2 psi per second) equalize the pressure between the high side and low side hoses, raising the gage (or manometer) reading at the relief opening of the differential pressure relief valve.
6. Repeat steps 4 and 5 for each 10 psi (68.9 kPa) increment between 20 psi (137.8 kPa) and the maximum working water pressure (MWWP), but not less than 100 psi (689.4 kPa) line pressure.
7. Failure of the differential pressure relief valve to open at or before 2.0 psi (13.75 kPa) requires, for all pressures designated in step 1, that the cause be reported.

**ASSE International**

Performance Requirements for  
**Reduced Pressure Principle Backflow Prevention Assemblies Standard #1013-2011**

**3.4 Relief Valve Opening Test**

**Purpose:**  
The purpose of this test is to verify that the differential pressure relief valve correctly opens under the specified conditions of the assembly.


**Procedure:**

- 1) Install the assembly as in Step 1, including a gage that will measure valve and differential pressure (range between 0 and 200 psi).
- 2) Close 14 and 15 to allow air to enter the assembly as in Step 1.
- 3) Close 12 and 13 to isolate the supply to 20 psi (137.8 kPa).
- 4) Slowly open the relief valve until a differential pressure is observed between the differential pressure when the high side of the valve comes out of the relief valve.
- 5) Close the relief valve. The relief valve shall be closed.
- 6) From a sufficient amount of water through the assembly, reduce a differential pressure that exceeds the test value. Repeat the assembly in a same condition.
- 7) Repeat the test increasing the supply pressure in 10 psi (68.9 kPa) increments up to the manufacturer's maximum working pressure of the assembly.


**Criteria:**

- 1) In differential pressure equal or less than 2 and 15.75 kPa or within the meaning of the relief valve shall result in a rejection of the assembly.
- 2) Closure of the relief valve to open the high side and a rejection of the assembly.


92



93



94




95


- RP Field Test Procedures**
- Order of Tests
  - Second Check Differential

96







97




98




99




100




101




102




103




104




105




106




107



108



109



110

*Manual of Cross-Connection Control, 5th Edition-1974*

- Field test procedures added for PVB

111

*Manual of Cross-Connection Control, 9th Edition-1993*

- Field test procedures added for SVB

112

*Manual of Cross-Connection Control, 7th Edition-1985*

- Field test procedures added preliminary steps (Notify, Identify, Inspect, Observe), and recommend yearly accuracy verification of gage equipment

113




114




115

### Gauge / Field Test Kit


- Handling / Holding the Field Test Kit
- Affecting your field testing results




116




117




118




119



120



121



122


**In Conclusion**

- Historical Development of Field Test Procedures
- Suitable for “Field” Use
- BEWARE of Shortcuts or Modifications
  - May produce false information
- Goal is the operation of the components to prevent Backflow

123





**Contact Information**


- Email – [fccchr@usc.edu](mailto:fccchr@usc.edu)
- Toll Free – 866.545.6340
- Web – [fccchr.usc.edu](http://fccchr.usc.edu)



124

**Social Media**

-  @uscfccchr
-  [facebook.com/uscfccchr](https://facebook.com/uscfccchr)
-  [youtube.com/uscfccchr](https://youtube.com/uscfccchr)
-  @uscfccchr



125

**Questions & Discussions**

126